

Science Building Inspection Form

Building _____ Date _____

Inspector _____

Areas of Inspection

Comments

Door:

- NFPA 704 **hazard labels** posted on door
- Chemical inventory** available
- Door signs** posted (emergency contacts, "Select Carcinogens," etc.)

Equipment:

- Guards** on mechanical equipment
- Proper **PPE** worn (gloves, goggles, etc.)
- Tools** in good condition
- Eyewash** stations function properly, tested weekly, unobstructed
- Safety showers** function properly, tested monthly, unobstructed
- Compressed **gas cylinders** secured properly
- All **refrigerators and freezers** labeled either for food or non-food use

Electrical and Fire:

- Power cords** (3-prong, good condition, commercial grade only)
- Power strips** w/ circuit breaker, no household extension cords
- Electrical panels** unobstructed
- 18" clearance** from fire sprinkler heads
- Nothing hanging from **sprinkler** heads, **pipes**, or **smoke detectors**
- 24" clearance** from ceiling
- Alarm pull-stations and fire extinguishers** clearly identified and unobstructed
- Fire extinguishers** (tamper seals in place, tags show inspection <1 yr old, 3 ft clearance)
